

Plett Pest & Borer

Pest Control

Woodborer Inspections and Treatments

Registration No P 1628 Act 36 of 1947 SAPCA No 0009

P.O.Box 261

pwborer@gmail.com

Mobile 083 228 9031

Plettenberg Bay 6600

Office: 044 533 6022

Inspection Report

Ref No: 1768

Date: 18.05.2021

Property:

Cnr Garden Street & Main Street, Keurboomstrand.

Description:

Triple storey under asbestos sheets.

Roof Area:

The timbers are Pine treated with CCA.

No signs of active infestation apparent.

Some sections splayed – roof timbers inaccessible.

Eaves:

Open and oiled.

No signs of active infestation apparent.

Floors:

Suspended wood strip. *Anobium punctatum* (Common

Furniture Beetle) noted in some floorboards of kitchen,

toilet, bathroom, end bedroom, lounge and front stoep. Also

in some bearers of front stoep.

Joinery:

Oiled wood. *Anobium punctatum* (Common Furniture Beetle)

noted in ceiling boards and partition boards of bathroom

Aux Roofs:

1. None.

Signed:



Malcolm Mottershead

for Plett Pest & Borer